

Application Note

Turns Ratio Testing – Test Results Analysis

The DV Power devices intended for transformer turns ratio measurement can be used to obtain both numerical and graphical results. The graphical results are available by using the DV-Win application software suite.

The transformer parameters measured by the TRT devices are the following:

- Transformer turns ratio;
- Turns ratio deviation;
- Excitation current;
- Phase angle.

Transformer turns ratio and ratio deviation

The turns ratio of a transformer is the ratio of a number of winding turns on each side of the transformer. The turns ratio measurement is performed by applying (and measuring) an AC voltage to one side (with higher number of turns) and measuring the output voltage. This test detects shorted turns, which indicate insulation failure. Shorted turns may result from short circuits with high currents or insulation failures.

The measured turns ratio should be compared to the transformer nameplate turns ratio (the specified ratio) data.

When using the DV-Win it is sufficient to enter the number of tap positions, and the voltage values of the first and the last tap position. The software application automatically calculates the voltage values for all tap positions. It is recommended to check voltage values for all tap positions in case of a non-linear tap changer regulation. The nameplate voltage of any tap position can be changed manually.

Position	Voltage V	Current A	Resistance (20 °C)	Connection
		ONAN	ONAF	
High-voltage				
Terminal: 1N - 1U - 1V - 1W				
1	122 500	178,2	296,9	266,4
2	120 000	181,9	303,1	258,1
3	117 500	185,7	309,6	249,5
4	115 000	189,8	316,3	241,1
5	112 500	194,0	323,3	232,6
6	110 000	198,4	330,7	224,2
7	107 500	203,0	338,4	215,7
8	105 000	207,8	346,4	207,2
9				
9A	102 500	212,9	354,9	197,9
9B				
10	100 000	218,2	363,7	210,9
11	97 500	223,8	373,1	202,4
12	95 000	229,7	382,9	193,9
13	92 500	235,9	393,2	185,4
14	90 000	242,5	404,1	176,9
15	87 500	249,4	415,7	168,4
16	85 000	256,8	427,9	159,9
Low-voltage				
Terminal: 2W - 2V - 2U - 2N				
	40 900	534	889	25,21

Tap selection

Primary/Secondary

Change OLTC direction

☒ OLTC position

	Primary voltage [V]	Secondary voltage [V]	Turns Ratio
<input checked="" type="radio"/> 1	122500.00	40900.00	3.00
<input type="radio"/> 2	120000.00	40900.00	2.93
<input type="radio"/> 3	117500.00	40900.00	2.87
<input type="radio"/> 4	115000.00	40900.00	2.81
<input type="radio"/> 5	112500.00	40900.00	2.75
<input type="radio"/> 6	110000.00	40900.00	2.69
<input type="radio"/> 7	107500.00	40900.00	2.63
<input type="radio"/> 8	105000.00	40900.00	2.57
<input type="radio"/> 9	102500.00	40900.00	2.51
<input type="radio"/> 10	100000.00	40900.00	2.44

START STOP

Show Results

Figure 1 Transformer nameplate voltages

Turns ratio deviation is an error indicator and shows the deviation as a percentage value of measured turns ratio and specified turns ratio. The turns ratio deviation value should not be more than 0,5% (IEC 60076-1, IEEE Std C57.12.00). The value can be

Ratio Deviation Phase A	Ratio Deviation Phase B	Ratio Deviation Phase C	Pass/Fail
0.23 %	0.24 %	0.23 %	Pass
0.23 %	0.20 %	0.23 %	Pass
0.24 %	0.25 %	0.24 %	Pass
0.23 %	0.20 %	0.24 %	Pass

Figure 2 Turns ratio deviation Pass/Fail test indicator

considered as “pass” or “fail” based on the turns ratio deviation value. The pass/fail criteria is 0,5% by default, but it can be changed in DV-Win. The turns ratio deviation graph consists of green and white areas. If results are in green area the test is consider as “passed”.




Figure 3 Turns ratio deviation green area is Pass/Fail test indicator

Excitation current and phase angle

The excitation current is the corresponding current flowing in the HV winding when the LV winding is open. The results can be compared to the reference results. It is important that both tests (that are compared) are performed with nearly the same test voltage values.

The excitation current value should be compared between the phases. The excitation current of the phases which are wound on outer core legs should be approximately equal. The value of the middle phase should be lower than the values of the outside phases. If the current values are not symmetrical as described, that can indicate a core failure or asymmetrical residual flux.

The transformer should be demagnetized before the excitation current test in order to get comparable results and avoid the residual flux influence.




Figure 4 Excitation currents for three phases

The phase angle and vector group detection test is important in transformer manufacturer factory to check whether the transformer windings are properly wound. Measuring the phase displacement is of interest to transformers intended for parallel operation. Also this test is important when three single phase transformers operate in a three-phase system (to check if transformer windings are properly connected). This measurement can also be used for checking phase shifting transformers, where each tap position has a different phase angle.

(Note: Find more explanation and case studies in the User guide section *Ratio Measurement and Problem Analysis*).